



VILNIUS, 11/01/2021

DECLARATION OF CONFORMITY NO.: B11/01/21-1

1. Producer: **BLUCAST JSC, Zirmunu str. 66, LT09131 VILNIUS, Lithuania**
2. Product name:
Gate valves 115 PN10/16 (F4, F5, BS) DN40 – DN600
3. Destination and product range to apply:
Ductile cast iron fittings are designed for installation in drinking, sewage water pipe lines, at the temperature of 70°C and the pressure up to 16 bar.
4. Documents of reference:
HYGIENIC CERTIFICATE – BK/W/0545/01-2018
WRAS CERTIFICATE– No.1606371
ACS CERTIFICATE – No.20ACC LY586
CHEMICAL TESTING DIVISION OF NATIONAL PUBLIC HEALTH SURVEILLANCE LABORATORY – Ch3529(Ch 3529)
5. Technical characteristics:
Range of diameters DN: 40 – 600
Flange end connections EN1092-2, ISO2531
Pressure class: PN16
Stem: stainless steel
Drilling of flanges: PN10/16, starting from DN200 – PN10 or PN16
Body material- ductile iron EN-GJS-500-7
Wedge – ductile iron GGG-50, EPDM coating
Coating- epoxy powder coating min. 250ym, RAL5015
PN-EN1074-1; PN-EN1074-2;

I declare with full responsibility that the products mentioned in point 2 are consistent with the documents of reference mentioned in point 4.

Sincerely,
General Manager
Tomas Čepaitis